

## Katrina Koshivos

---

**From:** Michael Killeen  
**Sent:** Tuesday, January 9, 2024 2:54 PM  
**To:** Katrina Koshivos  
**Subject:** 116 Upton Street

Good afternoon Katrina,

The only comment the Fire Department has is to ensure that upon construction / final inspection, all fire department connections on all buildings are within 100 feet of a fire hydrant, as the plans still do not appear to confirm this. Thank you.

Respectfully,  
Captain Michael Killeen  
Grafton Fire Department

RECEIVED  
JAN 09 2024  
Zoning Board of Appeals

RECEIVED TOWN CLERK  
GRAFTON, MA  
2024 JAN 10 AM 10:30